



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

Revised Report: Amended to add sample 23, 26 and 38 results

Otselic Valley Central School

Project Name: Jr-Sr. High School Lead Testing

Rick Shaw
125 County Road 13A
South Otselic, NY 13155

Project / PO Number: N/A
Received: 11/10/2016
Reported: 01/26/2017

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 104, Drinking Water, J6K0865-01, Client, 11/09/2016 6:06

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed. Row: Method: 200.8, Lead, 0.014, 0.015 AL, 0.001, mg/L, 12/05/16 0750, 12/09/16 0855

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 102 H, Drinking Water, J6K0865-02, Client, 11/09/2016 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed. Row: Method: 200.8, Lead, 0.0022, 0.015 AL, 0.001, mg/L, 12/05/16 0750, 12/09/16 0901

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 115 R A, Drinking Water, J6K0865-03, Client, 11/09/2016 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed. Row: Method: 200.8, Lead, 0.52, 0.015 AL, 0.001, mg/L, 12/05/16 0750, 12/09/16 0902

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values: 115 R B, Drinking Water, J6K0865-04, Client, 11/09/2016 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

Table with 8 columns: 200.8- ICP-MS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed. Row: Method: 200.8, Lead, 0.24, 0.015 AL, 0.001, mg/L, 12/05/16 0750, 12/09/16 0904



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 115 R C	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:22
<b>Lab Sample ID:</b> J6K0865-05	

**Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)**

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.15	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0906

<b>Client Sample ID:</b> 115 R E	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:25
<b>Lab Sample ID:</b> J6K0865-07	

**Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)**

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.21	0.015 AL	0.001	mg/L		12/06/16 0742	12/08/16 1033

<b>Client Sample ID:</b> 115 E A	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:25
<b>Lab Sample ID:</b> J6K0865-08	

**Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)**

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.38	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0908

<b>Client Sample ID:</b> 115 E B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:25
<b>Lab Sample ID:</b> J6K0865-09	

**Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)**

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.2	0.015 AL	0.001	mg/L		12/06/16 0742	12/08/16 1037



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 115 E C	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:30
<b>Lab Sample ID:</b> J6K0865-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.2	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0913

<b>Client Sample ID:</b> 115 E D	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:30
<b>Lab Sample ID:</b> J6K0865-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.13	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0920

<b>Client Sample ID:</b> 115 E E	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:23
<b>Lab Sample ID:</b> J6K0865-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.025	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0915

<b>Client Sample ID:</b> 115 E F	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:28
<b>Lab Sample ID:</b> J6K0865-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.022	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0917



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 115 E G	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:29
<b>Lab Sample ID:</b> J6K0865-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.056	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0919

<b>Client Sample ID:</b> 115 N	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:31
<b>Lab Sample ID:</b> J6K0865-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0038	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0924

<b>Client Sample ID:</b> 115 K	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:30
<b>Lab Sample ID:</b> J6K0865-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.011	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0926

<b>Client Sample ID:</b> 214	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:45
<b>Lab Sample ID:</b> J6K0865-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0097	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0928



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 211 B		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 6:46
<b>Lab Sample ID:</b> J6K0865-18		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.088	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0929

<b>Client Sample ID:</b> 110 Sink A		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:23
<b>Lab Sample ID:</b> J6K0865-19		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0018	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0935

<b>Client Sample ID:</b> 110 A		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:23
<b>Lab Sample ID:</b> J6K0865-20		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0017	0.015 AL	0.001	mg/L		12/05/16 0750	12/09/16 0937

<b>Client Sample ID:</b> 209 A		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:05
<b>Lab Sample ID:</b> J6K0865-21		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.012	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 0951



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 209 B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 7:12
<b>Lab Sample ID:</b> J6K0865-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.01	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 0956

<b>Client Sample ID:</b> 209 C	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 7:13
<b>Lab Sample ID:</b> J6K0865-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0089	0.015 AL	0.001	mg/L		12/05/16 0845	12/12/16 2107

<b>Client Sample ID:</b> 209 D	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 7:13
<b>Lab Sample ID:</b> J6K0865-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0081	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 0958

<b>Client Sample ID:</b> 209 E	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 7:13
<b>Lab Sample ID:</b> J6K0865-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.011	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1000



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 209 F		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:14
<b>Lab Sample ID:</b> J6K0865-26		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.01	0.015 AL	0.001	mg/L		12/05/16 0845	12/12/16 2108

<b>Client Sample ID:</b> 209 G		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:15
<b>Lab Sample ID:</b> J6K0865-27		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0057	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1002

<b>Client Sample ID:</b> 209 H		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:15
<b>Lab Sample ID:</b> J6K0865-28		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0064	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1004

<b>Client Sample ID:</b> 209 I		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:18
<b>Lab Sample ID:</b> J6K0865-29		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0092	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1009



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 209 J		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:18
<b>Lab Sample ID:</b> J6K0865-30		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.014	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1011

<b>Client Sample ID:</b> 209 K		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:19
<b>Lab Sample ID:</b> J6K0865-31		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.012	0.015 AL	0.001	mg/L		12/06/16 0742	12/08/16 1041

<b>Client Sample ID:</b> 209 L		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:20
<b>Lab Sample ID:</b> J6K0865-32		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.012	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1013

<b>Client Sample ID:</b> 209 M		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:20
<b>Lab Sample ID:</b> J6K0865-33		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0049	0.015 AL	0.001	mg/L		12/06/16 0742	12/08/16 1045





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 209 Eye Wash	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 7:08
<b>Lab Sample ID:</b> J6K0865-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0029	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1016

<b>Client Sample ID:</b> 209 Shower	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 7:10
<b>Lab Sample ID:</b> J6K0865-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0031	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1014

<b>Client Sample ID:</b> 210 A	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:58
<b>Lab Sample ID:</b> J6K0865-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0034	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1020

<b>Client Sample ID:</b> 210 B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 11/09/2016 6:58
<b>Lab Sample ID:</b> J6K0865-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0079	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1022



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 210 C	
<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J6K0865-38	<b>Collection Date:</b> 11/09/2016 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.013	0.015 AL	0.001	mg/L		12/05/16 0845	12/12/16 2112

<b>Client Sample ID:</b> 210 D	
<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J6K0865-39	<b>Collection Date:</b> 11/09/2016 6:59

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0076	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1023

<b>Client Sample ID:</b> 210 E	
<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J6K0865-40	<b>Collection Date:</b> 11/09/2016 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0067	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1025

<b>Client Sample ID:</b> 210 F	
<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J6K0865-41	<b>Collection Date:</b> 11/09/2016 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.014	0.015 AL	0.001	mg/L		12/06/16 0742	12/08/16 1048



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 210 G							
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client		
<b>Lab Sample ID:</b> J6K0865-42					<b>Collection Date:</b> 11/09/2016 6:58		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0063	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1031

<b>Client Sample ID:</b> 210 H							
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client		
<b>Lab Sample ID:</b> J6K0865-43					<b>Collection Date:</b> 11/09/2016 7:00		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0089	0.015 AL	0.001	mg/L		12/05/16 0817	12/09/16 1032

<b>Client Sample ID:</b> 210 I							
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client		
<b>Lab Sample ID:</b> J6K0865-44					<b>Collection Date:</b> 11/09/2016 7:00		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0099	0.015 AL	0.001	mg/L		12/05/16 0845	12/15/16 1431

<b>Client Sample ID:</b> 210 J							
<b>Sample Matrix:</b> Drinking Water					<b>Collected By:</b> Client		
<b>Lab Sample ID:</b> J6K0865-45					<b>Collection Date:</b> 11/09/2016 7:01		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.013	0.015 AL	0.001	mg/L		12/05/16 0845	12/15/16 1437



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 210 K		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:01
<b>Lab Sample ID:</b> J6K0865-46		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0056	0.015 AL	0.001	mg/L		12/05/16 0845	12/15/16 1438

<b>Client Sample ID:</b> 210 M		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:01
<b>Lab Sample ID:</b> J6K0865-47		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0061	0.015 AL	0.001	mg/L		12/05/16 0845	12/15/16 1440

<b>Client Sample ID:</b> 210 Emergency Shower		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:00
<b>Lab Sample ID:</b> J6K0865-48		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.011	0.015 AL	0.001	mg/L		12/05/16 0845	12/15/16 1442

<b>Client Sample ID:</b> 110 F		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:28
<b>Lab Sample ID:</b> J6K0865-49		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.014	0.015 AL	0.001	mg/L		12/05/16 0845	12/15/16 1444



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J6K0865

<b>Client Sample ID:</b> 110 R		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 7:23
<b>Lab Sample ID:</b> J6K0865-50		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.074	0.015 AL	0.001	mg/L		12/05/16 0845	12/12/16 2101

<b>Client Sample ID:</b> 109 B		<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water		<b>Collection Date:</b> 11/09/2016 6:50
<b>Lab Sample ID:</b> J6K0865-51		

Analyses Subcontracted to: Microbac Laboratories, Inc. Dayville (NY 11549)

200.8- ICP-MS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed
<b>Method: 200.8</b>							
Lead	0.0098	0.015 AL	0.001	mg/L		12/05/16 0845	12/12/16 2103

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

AL: Action Level  
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health
Microbac Laboratories, Inc. Dayville (NY 11549) NY Lab ID No.: 11549	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included.

Limits may be provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Reviewed and Approved By:

Andrew Canale  
Project Manager  
andrew.canale@microbac.com  
01/26/2017 15:55

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com